

Certificate**No. MPA-BS 6000/342-1E/20****Product**

Single and double-leaf steel door with resistance to fire properties
Dimensions (w x h clearance): 277 mm / 1,607 mm x 319 mm / 3,395 mm
575 mm / 3,335 mm x 319 mm / 3,395 mm
Trade name: Buchele 'PLANE Line'

Supplier

Buchele GmbH
Industriestraße 3
D-73061 Ebersbach / Fils

Production site

Buchele GmbH
Industriestraße 3
D-73061 Ebersbach / Fils

Resistance to fire**Classes: E 30, EI₁ 20, EI₂ 30, S₂₀₀, S_a, C5** according to EN 13501-2Explanation: Class E indicates integrity, class I₂ heat insulation, S smoke tightness and C durability.

Test standards: EN 1191, EN 1363-1, EN 1634-1 and EN 1634-3
Product standard: EN 16034 (Pedestrian doorsets, industrial, commercial, garage doors and openable windows)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products on the basis of the classification report No. K-2200/787/17-MPA BS of 22-01-2018.

Validity

This certificate shall be valid until 04-08-2025 as a maximum, provided that the product is not subject to changes, the product and the factory production control are inspected on a regular basis and the certification body does not withdraw it.

Braunschweig, 05-08-2020



W. Hinrichs
.....
Dr.-Ing. W. Hinrichs
Head of certification