

Certificate**No. MPA-BS 6000/342-2E/20****Product**

Single and double-leaf steel door with resistance to fire properties

Dimensions (w x h clearance): 277 mm / 1,397 mm x 319 mm / 2,952 mm
575 mm / 2,910 mm x 319 mm / 2,952 mm

Trade name: Buchele 'PLANE Line'

SupplierBuchele GmbH
Industriestraße 3
D-73061 Ebersbach / Fils**Production site**Buchele GmbH
Industriestraße 3
D-73061 Ebersbach / Fils**Resistance to fire****Classes: E 60, EI₁ 30, EI₂ 60, S₂₀₀, S_a, C5** according to EN 13501-2Explanation: Class E indicates integrity, class I₂ heat insulation, S smoke tightness and C durability.

Test standards: EN 1191, EN 1363-1, EN 1634-1 and EN 1634-3

Product standard: EN 16034 (Pedestrian doorsets, industrial, commercial, garage doors and openable windows)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products on the basis of the classification report No. K-2201/484/18-MPA BS of 29-01-2020.

Validity

This certificate shall be valid until 04-08-2025 as a maximum, provided that the product is not subject to changes, the product and the factory production control are inspected on a regular basis and the certification body does not withdraw it.

Braunschweig, 05-08-2020

Dr.-Ing. W. Hinrichs
Head of certification