

Certificate**No. MPA-BS 6001/158/16****Product**

The general purpose of smoke barriers is the protection against heat and smoke propagation. They are used as part of heat and smoke removal systems by closing large openings in buildings in case of fire. This makes it both easier for people to leave and for the fire fighters to enter burning buildings equipped with smoke barriers.

Model name: Smokemaster SM

Supplier

Colt International GmbH
Briener Str. 186
D-47533 Kleve
Germany

Fire testing

Class D120 according to EN 12101-1:2005+A1:2006 [Smoke and heat control systems – Part 1: Specification for smoke barriers]

Explanation: Class D120 indicates that the smoke barrier was successfully tested for 120 min at 600°C.

Certification procedure

The product has been assessed against the certification scheme MPA-BS 003 'Products for fire resistance and smoke control'. The certification body is accredited for EN 12101-1 under the No. D-ZE-11267-01-00 by Deutsche Akkreditierungsstelle GmbH (DAkkS) which is a signatory of the IAF-MLA.

Validity

This certificate shall be valid until 18-10-2018 as a maximum, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 19-10-2016


Dr.-Ing. Hinrichs
Head of Certification



Page 1 of 1