

This certificate of compliance validates the following

TEST REPORT NUMBER:	TPWR-1802/2500	CERTIFICATE NUMBER:	MPA BS-Z-082/18
DATE OF ISSUE:	18/03/2018	DATE OF ISSUE:	11/09/2018
DATE OF EXPIRY:	N/A	DATE OF EXPIRY:	07/05/2023

NAME OF FACTORY/ MANUFACTURER:	Fermacell GmbH	NAME OF THE BRAND:	Fermacell Gypsum Fibre Boards	CERTIFICATION MARK:	
FACTORY ADDRESS/REGION:	Fermacell B.V. Postbus 398 6600 AJ Wijchen, Niftrik, Netherlands +49 (0)203 60880-8321 Email: yury.khartanovich@xella.com	MODEL/NO:	Fermacell Gypsum Fibre Boards - 18 mm		
		LOGO ON THE PRODUCT:			

DESCRIPTION OF THE PRODUCT: Fermacell Gypsum Fibre Boards 120-minute Non-load-bearing partition wall system with overall nominal dimensions of 3000 mm high by 3000 mm wide and 136 mm thick.

TEST STANDARD: EN 1364-1:2015, EN 1363-1, EN 1363-2
TEST DESCRIPTION: The test was performed according to EN 1364-1 for 133 minutes up to about 1,050°C. The maximum acceptable temperature was reached after 123 minutes (insulation). The integrity of the sample was given for at least 133 minutes.

SPECIFICATION OF TEST SPECIMEN: Fire resistance and insulation for 120 minutes of a non-load-bearing wall system consisting of perimeter Insulation, partition tracks, partition studding, cavity insulation, cladding board, joint adhesive and joint sealant.

TEST RESULT:	MAINTENANCE OF FUNCTION CLASSIFICATION	INTERPRETATION	RESULT
		PASSED	120 minutes

NAME OF TEST FACILITY: MPA Braunschweig
TEST FACILITY ADDRESS/REGION: Beethovenstr. 52, D-38106 Braunschweig, Germany
Tel: ++49(0) 531 391 5400, Fax: ++49(0) 531 391 5900
Email: info@mpa.tu-bs.de, Website: www.mpa-tu-bs.de

PRODUCT APPLICATION GUIDELINE (END USE): To be used in buildings with requirements for resistance to fire. The product must be used according to the provisions in the manufacturer's manual. Prior to assembly and installation the personnel must be instructed.

SIGNED BY: 
Dr.-Ing. W. Hinrichs
Head of certification

The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'certification' and then on 'list of certificates'. You will find a list of manufacturers and a certificate with the number as given above.

ACCREDITED BY: DAKkS
AS PER: ISO/IEC 17065
VALIDITY: 01/10/2022
REFERENCE NUMBER: D-ZE-11267-01-00

Dubai Accreditation Department
ISO/IEC 17025
06/03/2010
LB-008-TEST

THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1363-1	Fire resistance tests Part 1: General requirements
EN 1363-2	Fire resistance tests Part 2: Alternative and additional procedures
EN 1364-1	Fire resistance tests for non-loadbearing elements Part 1: Walls

