

This certificate of compliance validates the following

TEST REPORT NUMBER: - CTICM-Metz (Efectis France): 08-V-364; 09-V-163; 10-V-152; 09-V-438; 09-V-437; 10-V-146; 10-V-151; 08-U-357; 10-V-142
CERTIFICATE NUMBER: MPA BS-Z-080/18

- ITB: LP-02802/09; LP-1328.1/08/e; LP-2200/09/e
- MPA Braunschweig: 3328/2686
- Istituto Giordano: 289689/3362FR
- IBS Linz: 091002001
- Efectis Niederlande: 2010-efectis-R0866; 2010-efectis-R0604
- Ift Rosenheim: 11-001355-PR01

DATE OF ISSUE: - 30/06/2009; 17/09/2009; 17/09/2009; 24/03/2010; 22/03/2010; 08/07/2010; 17/09/2010; 30/06/2009; 09/07/2010
DATE OF ISSUE: 2023-04-26

- 07/10/2010; 02/02/2009; 28/04/2011
- 09/01/2007
- 21/12/2011
- 22/02/2010
- October 2010; October 2011
- 19/05/2011

DATE OF EXPIRY: N/A **DATE OF EXPIRY:** 2028-04-25

NAME OF FACTORY/MANUFACTURER: Jansen AG
NAME OF THE BRAND: Janisol C4
CERTIFICATION MARK:
MODEL/NO: Janisol C4 EI60

FACTORY ADDRESS/REGION: Industriestrasse 34
CH-9463 Oberriet
Switzerland
Tel: +41 71 763 91 11
Email: info@jansen.com
LOGO ON THE PRODUCT:



DESCRIPTION OF THE PRODUCT: Fire-resistant doors (single- and double-leafed) as well as screens

TEST STANDARD: EN 1366-4 / 1363-1
TEST DESCRIPTION: Tests were performed in furnaces at temperatures of more than 900 °C on a test-frame for the wall constructions with various dimensions.

SPECIFICATION OF TEST SPECIMEN: Fire resistance and insulation of 60 minutes
 Max. dimensions (w x h):
 - single-leafed door 1400 mm x 2500 mm
 - double-leafed door 2760 mm x 2985 mm
 - screens 3960mm x 3112 mm / 2945 x 4500 mm

TEST RESULT:	MAINTENANCE OF FUNCTION CLASSIFICATION	INTERPRETATION PASSED	RESULT EI60
--------------	--	-----------------------	-------------

NAME OF TEST FACILITY: MPA Braunschweig
TEST FACILITY ADDRESS/REGION: Beethovenstr. 52, D-38106 Braunschweig, Germany
 Tel: +49(0) 531 391 5400, Fax: +49(0) 531 391 5900
 Email: info@mpa.tu-bs.de, Website: www.mpa.tu-bs.de
PRODUCT APPLICATION GUIDELINE (END USE): To be used in buildings with requirements for resistance to fire.
 The product must be used according to the provisions in the manufacturer’s manual. Prior to assembly and installation the personnel must be instructed.

The above certificate is valid only when installed in accordance with the ‘Product Application Guideline (End Use)’. To verify the validity of the product please log into our website, click on ‘certification’ and then on ‘list of certificates’. You will find a list of manufacturers and a certificate with the number as given above.

SIGNED BY: Dr.-Ing. Sven Lehmborg
 Head of certification

ACCREDITED BY:	DAkks	DAkks
AS PER:	ISO/IEC 17065	ISO/IEC 17025
VALIDITY:	N/A	N/A
REFERENCE NUMBER:	D-ZE-11267-01-00	D-PL-11267-01-02

ACCREDITED BY:	RvA	Cofrac	DAkks
AS PER:	ISO/IEC 17025	ISO/IEC 17025	ISO/IEC 17025
VALIDITY:	2025-01-01	2028-01-31	N/A
REFERENCE NUMBER:	RvA L470	COFRAC No. 1-1762	D-PL-11349-01-00

ACCREDITED BY:	BMWFV	Accredia	PCA
AS PER:	ISO/IEC 17025	ISO/IEC 17025	ISO/IEC 17025
VALIDITY:	N/A	2023-12-11	2025-06-27
REFERENCE NUMBER:	0042	0021L	AB 023

THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1363-1	Fire resistance tests Part 1: General requirements
EN 1364-1	Fire resistance tests for non-loadbearing elements – Part 1: Walls
EN 13501-2	Classification of building products and construction types as per their fire behaviour – Part 2: Classification using results from fire-resistance tests, excluding ventilation systems