


This certificate of compliance validates the following

TEST REPORT NUMBER:	- Applus: 08/32312654 - Efectis: 2010-Efectis-R0193	CERTIFICATE NUMBER:	MPA BS-Z-081/18
DATE OF ISSUE:	- 20/07/2009 - June 2010	DATE OF ISSUE:	2023-04-26
DATE OF EXPIRY:	N/A	DATE OF EXPIRY:	2028-04-25

NAME OF FACTORY/ MANUFACTURER:	Jansen AG	NAME OF THE BRAND:	Janisol C4	CERTIFICATION MARK:
		MODEL/NO:	Janisol C4 EI120	
FACTORY ADDRESS/REGION:	Industriestrasse 34 CH-9463 Oberriet Switzerland Tel: +41 71 763 91 11 Email: info@jansen.com	LOGO ON THE PRODUCT:		

DESCRIPTION OF THE PRODUCT: Fire-resistant screens

TEST STANDARD: EN 1366-4 / 1363-1
TEST DESCRIPTION: Tests were performed in furnaces at temperatures of more than 900 °C on a test-frame for the wall constructions with various dimensions.

SPECIFICATION OF TEST SPECIMEN: Fire resistance and insulation of 120 minutes
Max. dimensions (w x h): 3,000 mm x 3,000 mm

TEST RESULT:	MAINTENANCE OF FUNCTION CLASSIFICATION	INTERPRETATION	RESULT
		PASSED	EI120

NAME OF TEST FACILITY: MPA Braunschweig
TEST FACILITY ADDRESS/REGION: Beethovenstr. 52, D-38106 Braunschweig, Germany
Tel: +49(0) 531 391 5400, Fax: +49(0) 531 391 5900
Email: info@mpa.tu-bs.de, Website: www.mpa.tu-bs.de
PRODUCT APPLICATION GUIDELINE (END USE): To be used in buildings with requirements for resistance to fire.
The product must be used according to the provisions in the manufacturer's manual. Prior to assembly and installation the personnel must be instructed.

SIGNED BY: Dr.-Ing. Sven Lehmborg
Head of certification

The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'certification' and then on 'list of certificates'. You will find a list of manufacturers and a certificate with the number as given above.

ACCREDITED BY: DAKKS
AS PER: ISO/IEC 17065
VALIDITY: N/A
REFERENCE NUMBER: D-ZE-11267-01-00

ACCREDITED BY: RvA ENAC
AS PER: ISO/IEC 17025 ISO/IEC 17025
VALIDITY: 2025-01-01 N/A
REFERENCE NUMBER: RvA L470 No. 9/LE 895

THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1363-1	Fire resistance tests Part 1: General requirements
EN 1364-1	Fire resistance tests for non-loadbearing elements – Part 1: Walls
EN 13501-2	Classification of building products and construction types as per their fire behaviour – Part 2: Classification using results from fire-resistance tests, excluding ventilation systems