

Certificate

No. MPA-BS 6001/116/16

Product

Single or double leaf fire and smoke resistant wooden door with or without glazing
Nominal dimensions (H x W x T): 1,300 mm / 2,700 mm x 2,600 mm x 75 mm
Trade names: Type O / Type P

Supplier

Lindner AG
Bahnhofstr. 29
D-94424 Arnstorf
Germany

Fire-resistance**EI₂90 / EI₂60 for category A/B** according to EN 1634-1 and EN 13501-2

Explanation: E indicates the protection against the spread of fire and smoke for 60/90 min, I the protection of the integrity of the closure with this time-frame, 2 refers to the usual test procedure.

Test standards: EN 1363-1, EN 1634-1, EN 1634-3
Product standard: EN 16034 (Pedestrian doorsets, industrial, commercial, garage doors and openable windows)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products.

Validity

This certificate shall be valid until the 19-07-2018 as a maximum, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 20-07-2016


Dr.-Ing. Hinrichs
Head of Certification



Page 1 of 1

