

**This certificate of compliance validates the following**

<b>TEST REPORT NUMBER:</b>	<b>3296/1026/08 3782/045/07</b>	<b>CERTIFICATE NUMBER:</b>	<b>MPA BS-Z-062/17</b>
<b>DATE OF ISSUE:</b>	<b>2008-03-19 2010-01-26</b>	<b>DATE OF ISSUE:</b>	<b>2022-11-24</b>
<b>DATE OF EXPIRY:</b>	<b>N/A</b>	<b>DATE OF EXPIRY:</b>	<b>2027-11-23</b>

**NAME OF  
FACTORY/  
MANUFACTURER:** **NOVENCO Building &  
Industry A/S**

**NAME OF  
THE BRAND:** **NOVENCO**  
**MODEL/NO:** **NOVAX Type AUO, ARO  
Dia. 290 mm – 500 mm  
Class F300**

**CERTIFICATION MARK:**

**FACTORY  
ADDRESS/REGION:** **INDUSTRIVEJ 22  
DK-4700 NAESTVED  
Denmark  
Tel: +45 7077 88 99  
Email: info@novenco-  
building.com**

**LOGO ON  
THE  
PRODUCT:**



**DESCRIPTION OF  
THE PRODUCT:** Powered jet fans for car parks and tunnels including the removal of smoke at high temperatures, i.e. for operation at 300 °C for a minimum of 120 minutes.

**TEST STANDARD:** EN 12101-3  
**TEST DESCRIPTION:** Four ventilators were tested in an oven heated up to 300 °C by means of gas burners. Temperature measurements were done with thermocouples. During the test, temperature, volume flow, pressure and electrical values (current, voltage, etc) were measured. The test standard requires to stop the operation after 15 min for two minutes and to restart it.

**SPECIFICATION OF  
TEST SPECIMEN:** The axial flow fan tested had a diameter of 380 mm and a power input of 1.3 kW. It was equipped with silencers..

<b>TEST RESULT:</b>	<b>MAINTENANCE OF FUNCTION</b>	<b>INTERPRETATION</b>	<b>RESULT</b>
	<b>300 °C FOR 120 MIN</b>	<b>SUCCESSFUL</b>	<b>PASSED</b>

**NAME OF TEST FACILITY:** MPA Braunschweig

**TEST FACILITY ADDRESS/REGION:** Beethovenstr. 52, D-38106 Braunschweig  
Tel: +49(0) 531 391 5400, Fax: +49(0) 531 391 5900  
Email: info@mpa.tu-bs.de, Website: www.mpa-tu-bs.de

**PRODUCT APPLICATION GUIDELINE (END USE):** For use as a powered smoke and heat ventilators for temperatures up to 300 °C and for up to 120 min in a horizontal or a vertical position inside or outside the fire zone without thermal insulation.  
The ventilator can be used for dual operation (normal ventilation and hot smoke removal).  
The product must be applied in accordance with the provisions in the manufacturer's manual. Prior to installation the personnel must be instructed.

**SIGNED BY:**

Dr.-Ing. Sven Lehmberg  
Head of certification

The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'certification' and then on 'list of certificates'. You will find a list of manufacturers and a certificate with the number as given above.

<b>ACCREDITED BY:</b>	<b>DAkks</b>	<b>DAkks</b>
<b>AS PER:</b>	<b>ISO/IEC 17065</b>	<b>ISO/IEC 17025</b>
<b>VALIDITY:</b>	<b>N/A</b>	<b>N/A</b>
<b>REFERENCE NUMBER:</b>	<b>D-ZE-11267-01-00</b>	<b>D-PL-11267-01-02</b>

**THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)**

TEST STANDARD	TITLE
EN 12101-1	Smoke and heat control systems – Part 1: Specification for smoke barriers
EN 12101-2	Smoke and heat control systems – Part 2: Specification for natural smoke and heat exhaust ventilators
EN 12101-3	Smoke and heat control systems – Part 3: Specification for powered smoke and heat exhaust ventilators
EN 12101-6	Smoke and heat control systems – Part 6: Specification for pressure differential systems, Kits
EN 12101-7	Smoke and heat control systems – Part 7: Smoke duct sections
EN 12101-8	Smoke and heat control systems – Part 8: Smoke control dampers
EN 1366-8	Fire resistance tests for service installations – Part 8: Smoke extraction ducts
EN 1366-9	Fire resistance tests for service installations – Part 9: Single compartment smoke extraction ducts
EN 1366-10	Fire resistance tests for service installations – Part 10: Smoke control dampers
EN 13501-4	Fire classification of construction products and building elements – Part 4: Classification using data from fire resistance tests on components of smoke control systems

