

Certificate**No. MPA-BS 6000/392/20****Product**

Pipe penetration seal for fire protection purposes for use wall and floor constructions
Trade name: ROKU® System EC Endless Collar

Manufacturer

Rolf Kuhn GmbH
Jägersgrund 10
57339 Erndtebrück
Germany

Standards referred to for resistance to fire and fire behaviour of the product

Testing: EN 1366-3:2009 (Fire resistance tests for service installations - Part 3: Penetration seals) in connection with EN 1366-1:1999 (Fire resistance tests - Part 1: General Requirements)

Classification: EN 13501-2:2007+A1:2009 (Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services)

Product: EAD 350454-00-1104, September 2017 (Fire stopping and fire sealing products - Penetration seals)

Classification for:

Integrity, thermal insulation, fire behaviour

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products.

Validity:

This certificate shall be valid until 11-11-2022 as a maximum, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 12-11-2020

Dr.-Ing. Hinrichs
Head of Certification



Page 1 of 1