

Certificate

No. MPA-BS 6000/287/20

ProductLinear joint sealing for fire protection purposes for use in rigid wall constructions
Trade name: 'PYRO-SAFE® FLAMMOTECT-A'**Manufacturer**svt Brandschutz
Vertriebsgesellschaft mbH International
Glüsinger Straße 86
21217 Seevetal
Germany**Standards referred to for resistance to fire and fire behaviour of the product**

Testing: EN 1366-4:2010 (Fire resistance tests for service installations - Part 4: Linear joint seals)

Classification: EN 13501-2:2016 (Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services)

Product: EAD 350141-00-1106 (Fire Stopping and Fire Sealing Products - Linear Joint and Gap Seals)

Classification for:

Integrity (E), thermal insulation (I), orientation (H, V, T), movement (X), manufacturer and field (B), joint width range (W)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products.

Validity:

This certificate shall be valid until 2024-05-31 as a maximum, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 2022-06-01


Dr.-Ing. S. Lehmberg
Head of Certification

Page 1 of 1