

Certificate

No. MPA-BS 6000/282/20

Product

Textile fire protection curtain/closure

Trade name: Fire curtain 'Fibershield B'

Supplier

Stöbich Brandschutz GmbH
Pracherstieg 6
D-38644 Goslar
Germany

Test report

FIRES-FR-035-12-AUNE of 16 May 2012 on the basis of EN 1634-1:2008

Classification

The product has been classified for E 120-C0 / EW 30-C0 (report No. FIRES-JR-054-12-NURE ed. 2 of 17.04.2013).

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products. This includes an inspection of the factory production control on a regular basis.

Validity

This certificate shall be valid until 18-05-2022 as a maximum, provided that the product is not subject to changes.

Braunschweig, 19-05-2020

Dr.-Ing. Hinrichs
Head of Certification



Page 1 of 1