

Certificate**No. MPA-BS 6000/520/18****Product**

Single leaf steel door – realized as a hinged door
Nominal clearance dimensions (W x H x T): 1,200 mm x 2,100 mm x 100 mm
Trade names: KT/GT – T60 (hinged door)

Supplier

Torlit GmbH
Am Ellernbach 2
D-38871 Ilsenburg
Germany

and

cool it Isoliersysteme GmbH
Ochsenweg 18
D-49324 Melle
Germany

Fire-resistance**EI₂60** according to EN 1634-1 and EN 13501-2

Explanation: E indicates the protection against the spread of fire and smoke for 60 min, I the protection of the integrity of the closure with this time-frame, 2 refers to the usual test procedure.

Test standards: EN 1363-1, EN 1634-1
Product standard: EN 16034 (Pedestrian doorsets, industrial, commercial, garage doors and openable windows)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products.

Validity

This certificate shall be valid until the 2026-01-27 as a maximum, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 2021-01-28


Dr.-Ing. Hinrichs
Head of Certification



Page 1 of 1