

This certificate of compliance validates the following

TEST REPORT NUMBER:	CSI2313FR	CERTIFICATE NUMBER:	MPA-BS Z-103/20
DATE OF ISSUE:	2020-07-02	DATE OF ISSUE:	2020-10-07
DATE OF EXPIRY:	N/A	DATE OF EXPIRY:	2025-10-06

NAME OF FACTORY/ MANUFACTURER:	Wolf Sytem S.r.l.	NAME OF THE BRAND:	Wolf Haus	CERTIFICATION MARK:	-
		MODEL/NO:	Wolf Firewall 60		

**FACTORY
ADDRESS/REGION:** Zona Industriale Wolf 1
 39040 Campo di Trens (BZ)
 Italy
 Tel: +39 0472064000
 Email:
 michael.obermair@wolfsystem.it

**LOGO ON THE
PRODUCT:**

**DESCRIPTION OF
THE PRODUCT:** Load bearing walls in buildings with resistance to fire.

TEST STANDARD: EN 1363-1; EN 1365-1
TEST DESCRIPTION: Tests were performed in furnaces at temperatures of more than 900 °C on a test-frame for the wall construction with an applied vertical load of 45 kN/m.

CERTIFICATE NUMBER MPA-BS Z-103/20

**SPECIFICATION
OF TEST
SPECIMEN:** Fire resistance of 60 minutes
 Max. dimensions (w x h): 3000 mm x 3000 mm



TEST RESULT:	MAINTENANCE OF FUNCTION CLASSIFICATION	INTERPRETATION	RESULT
		PASSED	REI 60

NAME OF TEST FACILITY: C.S.I.S.P.A
TEST FACILITY ADDRESS/REGION: Viale Lombardia, 20/B, 20021 Bollate (MI), Italy
 Tel: +390238330376
 Email: info@csi-spa.com, Website: www.csi-spa.com
PRODUCT APPLICATION To be used in buildings with requirements for resistance to fire.
GUIDELINE (END USE): The product must be used according to the provisions in the manufacturer's manual. Prior to assembly and installation, the personnel must be instructed.

SIGNED BY: 
 Dr.-Ing. W. Hinrichs
 Head of certification

The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'certification' and then on 'list of certificates'. You will find a list of manufacturers and a certificate with the number as given above.

ACCREDITED BY: DAkKS
AS PER: ISO/IEC 17065
VALIDITY: 2022-10-01
REFERENCE NUMBER: D-ZE-11267-01-00

ACCREDIA
 ISO/IEC 17025
 2024-08-03
 0006L rev. 05



THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1363-1	Fire resistance tests Part 1: General requirements
EN 1365-1	Fire resistance tests for loadbearing elements Part 1: Walls