

This certificate of compliance validates the following

TEST REPORT NUMBER:	CSI2312FR	CERTIFICATE NUMBER:	MPA-BS Z-104/20
DATE OF ISSUE:	2020-07-02	DATE OF ISSUE:	2020-10-07
DATE OF EXPIRY:	N/A	DATE OF EXPIRY:	2025-10-06

NAME OF FACTORY/ MANUFACTURER:	Wolf Sytem S.r.l.	NAME OF THE BRAND:	Wolf Haus	CERTIFICATION MARK:	-
		MODEL/NO:	Wolf Firefloor 60		

FACTORY ADDRESS/REGION:	Zona Industriale Wolf 1 39040 Campo di Trens (BZ) Italy Tel: +39 0472064000 Email: michael.obermair@wolfsystem.it	LOGO ON THE PRODUCT:	
------------------------------------	--	---------------------------------	--

**DESCRIPTION OF
THE PRODUCT:** Load bearing floors in buildings with resistance to fire.


TEST STANDARD: EN 1363-1; EN 1365-2
**TEST
DESCRIPTION:** Tests were performed in furnaces at temperatures of more than 900 °C on a test-frame for the floor construction with an applied vertical load of 2.56 kN/m.

**SPECIFICATION
OF TEST
SPECIMEN:** Fire resistance of 60 minutes
Max. dimensions (w x l): 2943 mm x 4400 mm



TEST RESULT:	MAINTENANCE OF FUNCTION CLASSIFICATION	INTERPRETATION	RESULT
		PASSED	REI 60

NAME OF TEST FACILITY: C.S.I.S.P.A
TEST FACILITY ADDRESS/REGION: Viale Lombardia, 20/B, 20021 Bollate (MI), Italy
Tel: +390238330376
Email: info@csi-spa.com, Website: www.csi-spa.com
PRODUCT APPLICATION GUIDELINE (END USE): To be used in buildings with requirements for resistance to fire.
The product must be used according to the provisions in the manufacturer's manual. Prior to assembly and installation, the personnel must be instructed.

SIGNED BY:  Dr.-Ing. W. Hinrichs
Head of certification
The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'certification' and then on 'list of certificates'. You will find a list of manufacturers and a certificate with the number as given above.

ACCREDITED BY: DAkkS
AS PER: ISO/IEC 17065
VALIDITY: 2022-10-01
REFERENCE NUMBER: D-ZE-11267-01-00

ACCREDIA
ISO/IEC 17025
2024-08-03
0006L rev. 05



THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1363-1	Fire resistance tests Part 1: General requirements
EN 1365-2	Fire resistance tests for loadbearing elements Part 2: Floors and roofs