

This certificate of compliance validates the following

TEST REPORT NUMBER:	2200/544/16	CERTIFICATE NUMBER:	Z-094/19
DATE OF ISSUE:	20-02-2017	DATE OF ISSUE:	04-07-2019
DATE OF EXPIRY:	N/A	DATE OF EXPIRY:	03-07-2024

**NAME OF FACTORY/
MANUFACTURER:** abs Sicherungstechnik GmbH &
Co. KG

**FACTORY
ADDRESS/REGION:** Robert-Koch-Str. 19b
55129 Mainz
Germany

**NAME OF THE
BRAND:** abs

**MODEL/NO:
LOGO ON THE
PRODUCT:** EI SLIDE



BRANDSCHUTZ

**CERTIFICATION
MARK:**

**DESCRIPTION OF THE
PRODUCT:** Kit for a light-weight closure system for conveyor systems for fire protection purposes

TEST STANDARD: EN 1366-7

TEST DESCRIPTION: The test specimen consisted of a slide plate with three vertical elements, a sealing segment on the slide plate, a fixed field, conveyor technology and guiding rails. The test specimen was heated up in a furnace from room temperature to about 1,050°C within 117 min.

**SPECIFICATION OF
TEST SPECIMEN:** The dimensions of the closure system were 2,000 mm x 2,000 mm, of the slide plate 2,000 mm x 1,698 mm and of the fixed field 2,000 mm x 302 mm.

TEST RESULT:	MAINTENANCE OF FUNCTION	INTERPRETATION	RESULT
	FIRE INTEGRITY FOR AT LEAST 90 MIN	SUCCESSFUL	PASS
	INSULATION FOR AT LEAST 98 MIN	SUCCESSFUL	PASS
		EI 90	

NAME OF TEST FACILITY: MPA Braunschweig
TEST FACILITY Beethovenstr. 52, 38106 Braunschweig, Germany
ADDRESS/REGION: ++49(0)531-391-5400
Email: info@mpa.tu-bs.de, Website: www.mpa.tu-bs.de

**PRODUCT APPLICATION
GUIDELINE (END USE):** The assembled construction is installed with the appropriate connections according to the detailed prescriptions in the manual of the manufacturer. Prior to assembly and installation the personnel must be instructed.

SIGNED BY:



The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log into our website, click on 'others' and then on 'certificates'. You will find a list of manufacturers and a certificate with the number as given above.

ACCREDITED BY: DAKKS
AS PER: ISO/IEC 17065
VALIDITY: 1st OCTOBER 2022
REFERENCE NUMBER: D-ZE-11267-01-00

DAKKS
ISO/IEC 17025
13th NOVEMBER 2021
DE-PL-11267-01-02

THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

TEST STANDARD	TITLE
EN 1366-7	Fire resistance tests for service installations - Part 7: Conveyor systems and their closures

