

Braunschweig Civil Engineering Materials Testing Institute (MPA Braunschweig)

Beethovenstr. 52, DE-38106 Braunschweig, Germany Tel: ++49(0)531-391-5400 Fax: ++49(0)531-391-5900 Emall: info@mpa.tu-bs.de Website: www.mpa.tu-bs.de

UAE-007/14

2014-11-04

2019-11-03

This certificate of compliance validates the following

TEST REPORT NUMBER: P-3058/3412-MPA BS CERTIFICATE NUMBER:
DATE OF ISSUE: DATE OF EXPIRY: DATE OF EXPIRY:

DATE OF EXPIRY: DATE OF EXPIRY:

NAME OF FACTORY/ Brandchemie GmbH NAME OF THE BC-Brandschutz CERTIFICATION MARK:

MANUFACTURER: BRAND:

MODEL/NO:

FACTORY Auf der Trift 8 LOGO ON THE BC-Brandschutz-Farbe

ADDRESS/REGION: D-63329 Egelsbach PRODUCT:
Germany

Tel: +49 (0) 6103-9446-0 Fax: +49 (0) 6103-9446-17 Email: bc@brandchemie.de

DESCRIPTION OF THE Intumescent coating product for fire protection purposes to be applied on wood-based panels

PRODUCT: and solid wood plates

TEST STANDARD: DIN 4102-1

TEST DESCRIPTION: The reaction to fire of the product was tested. This test consists of tests of the fire behaviour.

SPECIFICATION OF TEST SPECIMEN:

The product was applied on chipboards

TEST RESULT: MAINTENANCE OF FUNCTION INTERPRETATION RESULT

CLASSIFICATION: B1 SUCCESSFUL PASS

NAME OF TEST FACILITY: MPA Braunschweig

stalt f.

TEST FACILITY

Beethovenstr. 52, 38106 Braunschweig, Germany

Tel: ++49(0)531-391-5400, Fax: ++49(0)531-391-5900

Email: info@mpa.tu-bs.de, Website: www.mpa.tu-bs.de

PRODUCT APPLICATION The intumescent coating is applied as a liquid for fire protection of internal timber and

GUIDELINE (END USE): wood derivates as well as of wood plates.

SIGNED BY:

The above certificate is valid only when installed in accordance with the 'Product Application Guideline (End Use)'. To verify the validity of the product please log ointo our website, click on 'others' and then on 'certificates'. You will find a list of manufacturers and a certificate with the number as given above.

PAGE 1 OF 2



Braunschweig Civil Engineering Materials Testing Institute (MPA Braunschweig)

Beethovenstr. 52, DE-38106 Braunschweig, Germany Tel: ++49(0)531-391-5400 Fax: ++49(0)531-391-5900 Email: info@mpa.tu-bs.de Website: www.mpa.tu-bs.de

ACCREDITED BY:

DAkkS

AS PER:

ISO/IEC 17065, ISO/IEC 17025

VALIDITY:

1st NOVEMBER 2017, 18th MARCH 2017

REFERENCE NUMBER:

D-ZE-11267-01-00, D-PL-11267-03-00

THE LIST OF ACCREDITED TESTS (FIRE AND LIFE SAFETY PRODUCTS ONLY)

Fire behaviour of building materials and building components – Part 1: Building materials – Definitions, requirements and test methods