

Certificate**No. MPA-BS 6000/489/21-2****Product**

Double-leaf aluminium door with resistance to fire properties
Dimensions: w x h = 2,168 mm x 2,500 mm
Trade name: Lindner door 'ADS 80 FR 60'

Manufacturer

Lindner SE
Bahnhofstr. 29
94424 Arnstorf
Germany

Lindner Türen-Fassaden s.r.o.
Karlovarská 1415
36301 Ostrov
Czech Republic

Test report

2011-Efectis-R0852[Rev.1] of 2009-06-05 according to EN 1634-1:2014+A1:2018

Classification:

The product has been classified **E 60, EI₁ 45, EI₂ 60, EW 60** (report No. 2019-Efectis-R002378 from 2020-03)

Certification procedure

The product has been assessed against the requirements of the MPA General Requirements for Certification of Fire Protection Products. This includes an inspection of the factory production control on a regular basis.

Validity:


This certificate shall be valid until 2023-05-05 at the latest, provided that the product is not subject to changes and the product and the factory production control are inspected on a regular basis.

Braunschweig, 2021-05-06

Dr.-Ing. S. Lehmann
Head of Certification



Product detail:



----- End of the certificate -----

